Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity

TÜVRheinland®

Zertifikat Nr. ***Certificate No.***
J 50745453

Blatt ***Sheet***
0001

Ihr Zeichen *Client Reference*	**Unser Zeichen** *Our Reference*	**Ausstellungsdatum**	*Date of Issue*
L.T.L.	01-BW-CN264Q9O 001	16.09.2026	*(day/mo/yr)*

Genehmigungsinhaber ***License Holder***
VIETNAM ELECTRIC CABLE CORPORATION
70-72 Nam Ky Khoi Nghia Street,
Sai Gon Ward,
70000 Ho Chi Minh City,
Vietnam

Fertigungsstätte ***Manufacturing Plant***
CADIVI DONGNAI CO.,LTD.
Line 1, Long Thanh Industrial Zone,
An Phuoc Commune,
76000 Dong Nai Province,
Vietnam

Prüfzeichen ***Test Mark***

TÜVRheinland® CERTIFIED
Safety
Regular Production Surveillance
www.tuv.com ID 1111322692

Geprüft nach ***Tested acc. to***
AS/NZS 5000.2:2006

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

(Electric cables—Polymeric insulated)

Type Designation	: HFI-90-TP 2x0,75 mm² (flat)	5
Ratings	: 450/750 V	
Mark of Origin	: CADIVI	

Remark:
1) Refer to test report CN264Q9O 001 for details.
2) Size 0,75 mm² is not included in AS/NZS 5000.2:2006.
3) Low smoke halogen free parallel-webbed 2-core flat flexible cords - ZCmo/LSHF can be used as below type: ZCmo/LSHF 450/750V 2x0,75 mm²

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH Zertifizierungsstelle

Zertifizierungsstelle

Bo Liu

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

10/020 d 04.08 ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.