



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLSAN 089558 0014 Rev. 01

Initial No. CLSAN 089558 0014 Rev. 00

Certificate Holder: Vietnam Electric Cable Corporation
(CADIVI)
70-72 Nam Ky Khoi Nghia Street
Nguyen Thai Binh Ward, Dist 1
700000 Ho Chi Minh City
VIETNAM

UEN - 0300381564

Certification Mark:



TÜV SÜD PSB

Product: Flame retardant cables

Brand Name: CADIVI

Model(s): Refer to following page(s)

Product Details: Refer to following page(s)

Standard(s): IEC 60332-3-24:2000/AMD1:2008
IEC 60754-1:2011
IEC 60754-2:2011
IEC 61034-2:2005/AMD1:2013

Country of Origin: Vietnam

Test Report(s): 7191234638-EEC20/05, 7191234638-EEC20/06

Valid until: 2025-11-18

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Issued on: 2021-01-18

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLSAN 089558 0014 Rev. 01

Initial No. CLSAN 089558 0014 Rev. 00

Model(s):

CXE/AWA/FRT-LSHF 4X16 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X25 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X35 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X50 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X70 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X95 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X120 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X150 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X185 - 0.6/1KV
CXE/AWA/FRT-LSHF 4X240 - 0.6/1KV

Product Details:

Type : CU/XLPE/AWA/FRT-LSHF Cable
Voltage : 600/1000V
Conductor : Stranded Circular Plain Copper Wires (class 2)
Insulation : XLPE-Natural With Tape-Red, Yellow and Blue
Filler : PP-LSHF
Binder : PET-LSHF Tape
Inner Covering : LSHF-Black
Armour : Round Aluminium Wires (AWA)
Binder : PET-LSHF Tape
Sheath : LSHF-Black
Sizes : 4C x 16mm² to 4C x 240mm²

Page 2 of 2

Issued on: 2021-01-18

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg