

# Zertifikat

# Certificate



**Zertifikat Nr. Certificate No.**  
R 50555675

**Blatt Sheet**  
0001

**Ihr Zeichen Client Reference**  
L.T.L.

**Unser Zeichen Our Reference**  
01-SYF-CN22XQHV 001

**Ausstellungsdatum Date of Issue**  
07.09.2022 (day/mo/yr)

**Genehmigungsinhaber License Holder**  
VIETNAM ELECTRIC CABLE CORPORATION  
70-72 Nam Ky Khoi Nghia str.  
Nguyen Thai Binh ward,  
Dist. 1 Ho Chi Minh city 70000  
Vietnam

**Fertigungsstätte Manufacturing Plant**  
VIETNAM ELECTRIC CABLE CORPORATION  
70-72 Nam Ky Khoi Nghia str.  
Nguyen Thai Binh ward,  
Dist. 1 Ho Chi Minh city 70000  
Vietnam

**Prüfzeichen Test Mark**



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111258246

**Geprüft nach Tested acc. to**  
AS/NZS 5000.1:2005

**Zertifiziertes Produkt (Geräteidentifikation)**  
**Certified Product (Product Identification)**

**Lizenzentgelte - Einheit**  
**License Fee - Unit**

Cable (Electric cables-Polymeric insulated)

Type Designation : CV/FR-0,6/1 kV 1X1,5...630mm<sup>2</sup> CADIVI 12  
Rated Voltage : AC 0,6/1,0kV  
Max. Temperature at Conductor : 90°C

Remark: Category C for IEC 60332-3-24:2018  
Protocol CZ for BS 6387:2013

12

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



**Zertifizierungsstelle**

**Kenny Shi**

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

http://www.tuv.com/safety E-mail: markcheck@tuv.com  
Fax: +49 221 806-3935