



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLSAN 089558 0029 Rev. 00

Initial No. CLSAN 089558 0012 Rev. 00

**Certificate Holder:** Vietnam Electric Cable Corporation  
(CADIVI)  
70-72 Nam Ky Khoi Nghia Street  
Nguyen Thai Binh Ward, Dist 1  
70000 Ho Chi Minh City  
VIETNAM

UEN - 0300381564

**Certification Mark:**



TÜV SÜD PSB

**Product:** Flame retardant cables  
**Brand Name:** CADIVI  
**Model(s):** Refer to following page(s)  
**Product Details:** Refer to following page(s)  
**Standard(s):** IEC 60332-3-24:2000/AMD1:2008  
IEC 60754-1:2011  
IEC 60754-2:2011  
IEC 61034-2:2005/AMD1:2013  
**Country of Origin:** Vietnam  
**Test Report(s):** 7191234638-EEC20/03, 7191234638-EEC20/04  
**Valid until:** 2030-11-18

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

**Issued on:** 2025-11-13

Vice-President (Certification Department)  
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuvsud.com/sg](http://www.tuvsud.com/sg)



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLSAN 089558 0029 Rev. 00

Initial No. CLSAN 089558 0012 Rev. 00

## Model(s):

CXE/AWA/FRT-LSHF 16 - 0.6/1KV  
CXE/AWA/FRT-LSHF 25 - 0.6/1KV  
CXE/AWA/FRT-LSHF 35 - 0.6/1KV  
CXE/AWA/FRT-LSHF 50 - 0.6/1KV  
CXE/AWA/FRT-LSHF 70 - 0.6/1KV  
CXE/AWA/FRT-LSHF 95 - 0.6/1KV  
CXE/AWA/FRT-LSHF 120 - 0.6/1KV  
CXE/AWA/FRT-LSHF 150 - 0.6/1KV  
CXE/AWA/FRT-LSHF 185 - 0.6/1KV  
CXE/AWA/FRT-LSHF 240 - 0.6/1KV  
CXE/AWA/FRT-LSHF 300 - 0.6/1KV

## Product Details:

Type : CU/XLPE/LSHF/AWA/FRT-LSHF Cable  
Voltage : 600/1000V  
Conductor : Stranded Circular Plain Copper Wires (class 2)  
Insulation : XLPE-Natural  
Inner Covering : LSHF-Black  
Armour : Round Aluminium Wires (AWA)  
Binder : PET-LSHF Tape  
Sheath : LSHF-Black  
Sizes : 1C x 16mm<sup>2</sup> to 1C x 300mm<sup>2</sup>

## Replacement History:

Predecessor Certificate (Issue Date)  
CLSAN 089558 0012 Rev. 00 (2020-11-19)  
CLSAN 089558 0012 Rev. 01 (2021-01-18)

Page 2 of 2

Issued on: 2025-11-13

Vice-President (Certification Department)  
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuvsud.com/sg](http://www.tuvsud.com/sg)